

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7256-1498:100 Page 1 of 1

CATEGORY: Single/Multiple Station Smoke Detector-Ionization

LISTEE: Tel-Tron Technologies, 220 Fentress Blvd., Daytona Beach, FL 32114
Contact: Rick Dawson (904) 255-1921

DESIGN: Model SDIA single station, ionization type smoke detector unit with Model SDIA-BC1, -BC2, -BG1, -BG2, BO1, -BO2 or -BGP base. Unit is a listed Maple Chase's Model A or B single station smoke detector (CSFM Listing No. 7256-1093:109) with the battery holder and battery attachment clip removed and replaced by a two terminal wiring board, pigtail leads and end of line (EOL) resistor. The unit must be used with Model MICI Interface Cabinet which provides the power for the detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10 VDC

INSTALLATION: In accordance with listee's printed instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as single station, ionization type smoke detector and base for use only with listee's separately listed Model Microscan MICC, MICI and MICA smoke detector accessories (CSFM Listing No. 7300-1498:101). Depending on the application, the authority having jurisdiction should be consulted prior to installation.

NOTE: Models MICI, MICA or MICC are not fire alarm control panel.

09-22-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 22, 2001**

Listing Expires June 30, 2002

Authorized By: **BEN HO**, Supervising Deputy
Program Manager